



**Bullistic Barriers LLC** provides Bullet Resistant products that provide aesthetically pleasing ballistic protection that eliminates ricochet, is non-combustible, and is practically unscalable.

For additional information, contact:

**Bullistic Barriers LLC**

1406 West Kings Highway  
Gap, PA 17527

Phone: +1 717-869-2775

Web: [www.bullisticbarriers.com](http://www.bullisticbarriers.com)

Email: [office@bullisticbarriers.com](mailto:office@bullisticbarriers.com)

## BULLET RESISTANT FENCE

**MasterFormat 2020:**

**Section 32 31 00      Fences and Gates**

### Notes to Specifier:

1. Where several alternative parameters or specifications exist, or where, the specifier has the option of inserting text, such choices are presented in **<bold text>**.
2. Explanatory notes and comments are presented in *italicized colored* text.

## CLASS 2 BULLET RESISTANT FENCE

### PART 1 GENERAL

#### 1.01 SUMMARY

- A Section includes an aluminum fence, furnished with all components, and designed and tested to provide bullet resistance per UL-752, Standard for Bullet-Resisting Equipment, levels 1, 2, 3, and 6.
- B Related Requirements
  - 1. Division 03 Concrete
    - a. 03 00 00 Concrete
  - 2. Division 08 Openings
    - a. 08 34 56 Security Gates
  - 3. Division 28 Electronic Safety and Security
    - a. 28 10 00 Access Control
  - 4. Division 31 Earthwork
    - a. 31 60 00 Special Foundations and Load Bearing Elements

#### 1.02 REFERENCES

- A Reference Standards
  - 1. Underwriters' Laboratories (UL)
    - a. UL 752 - Standard for Bullet-Resisting Equipment
      - 1) Level 1: 9 mm, 124 grain, full metal copper jacket with lead core; 1175 -1293 ft/sec;  
3 shots
      - 2) Level 2: .357 Magnum, 158 grain, jacketed lead soft point; 1250 - 1375 ft/sec;  
3 shots
      - 3) Level 3: .357 Magnum, 240 grain, lead semi-wadcutter gas checked; 1350 - 1485 ft/sec;  
3 shots
      - 4) Level 6: 9 mm, 124 grain, full metal copper jacket with lead core; 0400 - 1540 ft/sec;  
5 shots
      - 5) Level 4: 30 30-06, 180 grain, lead semi-wadcutter gas checked; 2540 to 2794 ft/sec;  
1 shot
      - 6) .30 7.62, 150 grain, full metal copper jacket with lead core; 2750 to 3025 ft/sec.  
1 shot
      - 7) Level 7: .223 5.56, 55 grain, full metal copper jacket with lead core; 3080 to 3388 ft/sec.  
5 shots
      - 8) Level 8: .30 7.62, 150 grain, full metal copper jacket with lead core; 2750 to 3025 ft/sec  
5 shots
      - 9) Level 1: Thru 3 SG 12 gauge 2 3/4"  
1 shot
      - 10) Level 1: Thru 3 SG 12 gauge Buckshot

1 shot

2. National Institute of Justice (NIJ)
    - a. NIJ Standard 0108.01 Ballistic Resistant Protective Materials, Armor Types I , II, III
  3. MIL-SAMIT Ballistic Standards
    - a. MIL-SAMIT .30 7.62 NATO, 147 grain M80; 2750 to 2850 ft/sec
- 25 shots
4. ASTM International
    - a. ASTM B117 - Practice for Operating Salt-Spray (Fog) Apparatus
    - b. ASTM B221 - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles and Tubes
    - c. ASTM D822 - Practice for Conducting Tests on Paint and Related Coatings and Materials using Filtered Open-Flame Carbon-Arc Light and Water Exposure Apparatus

### **1.03 SUBMITTALS**

- A Product Data
1. Manufacturer's printed or electronic data sheets
  2. Manufacturer's installation and operation manuals
  3. Independent testing agency certification of product performance satisfactory to Owner's representative.

### **1.04 QUALIFICATIONS**

- A Manufacturer's products shall be manufactured in the United States of America.

## **END OF SECTION**

## **PART 2 PRODUCTS**

### **2.01 EQUIPMENT**

- A Manufacturer: Bullistic Barriers, LLC  
1406 West Kings Highway  
Gap, PA 17527  
Phone: +1 717 869-2775  
Web: [www.bullisticbarriers.com](http://www.bullisticbarriers.com)  
E-mail: [office@bullisticbarriers.com](mailto:office@bullisticbarriers.com)
- B Models: Class 2 Fence
- C Alternates: None

### **2.02 DESCRIPTION**

- A The Class 2 bullet-resistant fence ("fence") shall be an aluminum fence skeleton, furnished with all components required to provide a complete structure including panels, panel tops, posts, post caps, and gates.

## 2.03 MATERIAL

- A Material for the fence structure, to include posts, panel skins and panel tops, shall be aluminum conforming to ASTM B221.
  - 1. Aluminum extrusions shall conform to Alloy and Temper Designation 6063 T5 or 6061 T-6.
- B The engineered panel shall be processed through a 7 step, blasting, multi-stage pretreatment, prime and powder-coat topcoat. Topcoat shall be Tiger Drylac AAMA 2604 Super Durable Series 38 Argento 314 38/90018.
- C Aluminum castings shall be used for post caps.  
*In a coastal environment, specify Alloy 535 for maximum corrosion resistance.*

## 2.04 CONSTRUCTION

- A Posts to accept the fence panels shall be 6" square H-posts.
- B Post spacing shall be 10 feet on-center unless otherwise noted in drawings.  
*10 foot is typical spacing value for a 119 inch wide panel with a 2 foot louver top. Consult factory for additional height options and spacing requirements.*
- C The fence panel shall be 2 ½ inch nominal thickness in a tongue and groove design.
- D Footing as specified is calculated to 90mph wind load.

## 2.05 PERFORMANCE

- A The fence shall meet the following ballistic requirements:
  - a. UL-752 Levels 1, 2, 3, 4, 5, 6, 7 and 8
  - b. NIJ-I, NIJ-II, NIJ-III, 2 levels of ammo, 5 shots
  - c. 12 GA. shotgun, 2 ¾ slug and buck shot
  - d. MIL-SAMIT .30 7.62 NATO

## 2.06 AESTHETIC

- 1. The Manufacturer shall offer as a minimum the following appearance options:
  - a. Cascade
  - b. Classic
  - c. Contemporary
  - d. Louvre
    - d1. Louvre can be placed at a 45-degree angle for wind to pass through but engineered to provide Class 1 Bullet Resistance on a horizontal plane.
    - d2. Louvre can be placed at a 45-degree angle for wind to pass through but engineered to provide Class 2 Bullet Resistance on a horizontal plane.
  - e. Modern
  - f. Villanova

## END OF SECTION

## PART 3 EXECUTION

### 3.01 INSTALLERS

- A Installers will be pre-accredited by Bullistic Barriers LLC.
- B Contractor personnel shall comply with all applicable state and local licensing requirements.

**3.02 PRODUCT HANDLING AND STORAGE**

- A Upon receipt at the job site, all materials shall be verified to ensure that no damage occurred during shipping or handling. Materials shall be stored in such a way that will ensure protection from damage, weather, vandalism and theft.

**3.03 PREPARATION**

- A All new installation shall be laid out by the contractor in accordance with the construction plans.

**3.04 INSTALLATION**

- A Contractor shall follow Manufacturers recommended installation guidelines.
- B Fence Installation
  - 1. Post holes shall be dug, and posts shall be installed in accordance with engineered specifications. Details include rebar location/ diameter/ number, hole depth/ width, and properly concreted.
  - 2. Drilling holes, cutting open, or otherwise tampering with the ballistic integrity of the manufactured Class 2 panel shall be prohibited without the clear written consent of the Manufacturer.
- C Gate Installation
  - 1. Gate posts shall be spaced according to the manufacturers' gate drawings. Manufacturer's provided hinges and hardware shall be installed in conformance with intended application.

**END OF SECTION**